

CONTRACT ADDENDUM

ADDENDUM NO.: 001

DATE ISSUED: Friday December 1, 2023

PROPOSAL DUE DATE: Friday December 8, 2023

DUE TIME: 12 PM ET

LOCATION: City of Dalton Finance Department

CONTRACTOR ACTION:

1. Acknowledge receipt of this addendum by writing in "Addendum No. 1" on proposal.

INTERPRETATIONS:

Responses by the City of Dalton follow the questions in red font.

1. In reference to Section 3.0, E, page 5 for the Camera, Access Control, Cabling Upgrades bid, are C-7 and RCDD certification still standing as minimum requirements to submit for this bid, or will the vendor's score be reduced by 5 points if they do not have these certifications?
 - a. I think the best answer, if I understand the question correctly, is that it would reduce the score by 5 points but not eliminate the vendor as long as they are willing to follow RCDD standards with the installation.
2. Is the vendor providing card readers, or do you already have them? If the vendor must provide, what is the quantity?
 - a. In the document handed out on the site visit day, it specifies that the vendor is providing the card readers.
 - b. We strongly encourage you to read through the detailed document we handed out the day of the walkthrough, City of Dalton Physical Security Systems Upgrade, to confirm the items that the vendor is responsible for. Below are the number of card readers we believe necessary to complete this project.

Part Number	Qty
HID 40KNKS-00-000000	12
HID 40NKS-00-000000	16
HID 20KNKS-00-000000	1

3. Is the vendor providing locks, or do you already have them? If the vendor must provide, what is the quantity?
- a. In the document handed out on the site visit day, it specifies that the vendor is providing the card readers.
 - b. We strongly encourage you to read through the detailed document we handed out the day of the walkthrough, City of Dalton Physical Security Systems Upgrade, to confirm the items that the vendor is responsible for. Below are the number of door strikes we believe necessary to complete this project.

Part Number	Qty
HES 9500-630-LBM	2
HES 8300C-630-LBM	14

4. Would the City of Dalton consider installing door strikes in the glass doors at the Police department?
- a. The City of Dalton would prefer to move away from mag locks when possible, while maintaining the aesthetics of the glass doors.
5. Would the City of Dalton consider installing new access control composite cable at the Police department?
- a. Yes, due to the age of the cable and recommendations from the experts.
6. The handout provided at the mandatory meeting did not include an additional camera that needed to be removed at the Police department.
- a. A new copy of that diagram has been updated and emailed.
7. Due to the short notice for the mandatory meeting today and the holiday, we were not able to get representation for this visit. Is it possible to still allow us to participate in the bidding process or to have an onsite meeting at a later date? We would hate to miss the opportunity to showcase our solution.
- a. I am sorry, but all the bidders needed to attend the mandatory meeting to qualify for the bid.
8. Would the City of Dalton entertain an operating expense model?
I believe that is not part of the proposed scope.
I ask because we work and provide service utilizing Cisco Meraki cameras but service is provided as a service to include all support, co-management, licensing, design, cabling etc.. We do not though sell equipment as a customer capital expense.

The City of Dalton has already purchased all of the equipment. The project scope will be for the installation of the equipment and pulling of new cable.

9. Would a partial proposal be entertained just for video surveillance cameras?

We would like to see a proposal for all of the work.

We do not provide access control systems.

You may submit a proposal without access control.

BY:

Jorge Paez
Information and Technology Director

Attachments: None