
RFP ADDENDUM

ADDENDUM NO.: 004

DATE ISSUED: April 15, 2024

BID DATE: Thursday, April 18, 2024

BID TIME: 2:00 PM ET

BID LOCATION: City of Dalton Finance Department

QUESTIONS:

1. "When it comes to the access control and camera portion of the project, are the vendors of the equipment doing the installation or does this fall under number 28 Division 27 of the base proposal."

Answer: Access control and security materials and labor will be provided by the Owner's vendors through a separate RFP process. Subcontractors providing a proposal for the Renovations & Additions to the John Davis Recreation Center RFP will only be responsible for the materials and labor specified in the project manual and shown or detailed on the drawings for this project. Subcontractors will be required to help coordinate work if trade interaction is required with Owner's vendors.

MODIFICATIONS:

1. E2.11: PAB Power Plan and HVAC Power Plan
 - a. Showers 107 and Showers 112: Both changing stations are manual and do not require power. In lieu of changing table connection, provide duplex receptacle outlet mounted at 18" AFF.

SUBSTITUTIONS:

1. 096466: Wood Athletic Flooring
 - a. Action ProAir AR is an approved substitution. Substitution must meet or exceed the specification Quality Standard.
2. 126600: Telescopic Seating
 - a. Kodiak Seating Systems is an approved substitution. Substitution must meet or exceed the specification Quality Standard.