

DATE: March 28, 2024

TO: ALL BIDDERS OF RECORD

PROJECT NAME: A New Building for: Dalton Police Department  
For The City of Dalton, GA

PROJECT NUMBER: 23-021

FROM: KRH Architects  
855 Abutment Road  
Suite 4  
Dalton, GA 30721

PRIME BIDDERS ACKNOWLEDGE THE RECEIPT OF THIS ADDENDUM BY INSERTING THE NUMBER AND DATE IN THE APPROPRIATE POSITION ON THE PROPOSAL FORM. FAILURE TO DO SO MAY SUBJECT THE BIDDER TO DISQUALIFICATION. THIS ADDENDUM IS A PART OF THE CONTRACT DOCUMENTS. IT MODIFIES THEM AS FOLLOWS:

---

**Item No. 1****Section 00010**

The Time and Date for the receipt of proposals has been changed.

**Sealed proposals will be received by the City of Dalton Finance Department located at 300 W. Waugh Street, Dalton, Georgia 30720 until: 10:00 A.M. on the 5th day of April 2024.** All proposals must be sealed and plainly marked "New Building for Police Department". A total of **2** proposals in bound notebooks are required. Please tab each section/form individually. Any Proposal received after said time will not be accepted. At the discretion of the City and in conformity with the applicable laws of the State of Georgia, the City may afford contractors an opportunity for subsequent discussion, negotiation, and revision of Proposals. The City reserves the right to reject any or all Proposals and to waive any technicalities or formalities.

**Item No. 2****M0.1**

The following note shall supersede the previous note added to the bottom of M0.1.

PROVIDE HVAC BAS CONTROLS FOR ALL SPLIT FURNACE UNITS, MINI-SPLIT SYSTEMS, AND DEDICATED OUTSIDE AIR SYSTEM. CONTROL SYSTEM SHALL BE SIEMENS TALONS AND PROVIDE POINTS AND LOGIC PER THE SEQUENCE OF OPERATIONS ON SHEET M0.4. PROVIDE BACnet CARDS AS REQUIRED IN EACH UNIT. PROVIDE WALL SENSORS w/ TEMPORARY OVERRIDE, WHERE SHOWN AS THERMOSTAT ON PLANS. SYSTEM SHALL BE CAPABLE OF BEING MONITORED ON-SITE w/ SCHEDULING. CONTACT ALEX BROWN w/ FRAZIER SERVICE COMPANY FOR CONTROL PACKAGE.

**END OF ADDENDUM No4**