

CONTRACT ADDENDUM

ADDENDUM NO.: 001

DATE ISSUED: July 7, 2021

BID DATE: Tuesday, July 13, 2021

BID TIME: 2 PM ET

BID LOCATION: Dalton City Hall Finance Department

CONTRACTOR ACTION:

1. Acknowledge receipt of this addendum by writing in "Addendum No. 1" on page 0200-3 of bid proposal.

INTERPRETATIONS:

Responses by the City of Dalton follow the questions in red font.

1. Please clarify the work hours on the commercial & industrial streets. It states no work between 7:01 am to 7:59 am, but stopping time is not listed. **The work hours for the commercial and industrial streets will only be restricted during the AM Rush between 7:01 AM and 7:59 AM.**
2. Should the finished asphalt be flush with the gutter or will the contractor only mill 1.5" and resurface the existing asphalt? **The Contractor shall only mill 1.5" and resurface the asphalt.**
3. Will the parking areas on Morris Street and Underwood Street be included in the milling and resurfacing areas? **Yes, the parking areas shall be included.**
4. Will railroad insurance be required on Morris Street and Emery Street? **No, we will not mill or resurface into the Railroad Right of Way.**

BY:

Megan Elliott
Project Manager

###