

CONTRACT ADDENDUM

ADDENDUM NO.: 001

DATE ISSUED: April 01, 2021

BID DATE: Tuesday, April 6, 2021

BID TIME: 2 PM ET

BID LOCATION: City of Dalton Finance Department

CONTRACTOR ACTION:

1. Acknowledge receipt of this addendum by writing in "Addendum No. 1" on page 0200-3 of bid proposal.
2. Please remove and discard the original bid form from the bid proposal. Each Contractor shall record their bid on the revised bid form attached to this document. Failure to use the revised bid form will result in automatic rejection of the bid submitted.

INTERPRETATIONS:

Responses by the City of Dalton follow the questions in red font.

1. Can Stoneleigh Drive be closed to thru traffic during work hours since it connects to both Walnut Avenue and Lakemont Drive? **No, only single lane closures are allowed.**
2. What are the hours that the contractor will be allowed to install lane closures for this project? **Lane closures are permitted between 7:01 AM and 8:59 PM.**
3. The bid documents state that the house will be removed by the City. Will the City also be removing the existing driveway and sidewalks to the house? **The City will be removing the house prior to the project start. However, the Contractor will be responsible for the removal of the existing footers, the existing driveway, and the existing sidewalk.**
4. It appears that based on the pay items that the intent is to fully backfill the trenches in the roadway with TP 2 Backfill. Please Confirm. **This item is addressed in the bid package under Section 400 note 13. Please refer to the detail provided there.**
5. The two new junction boxes that are being installed on Stoneleigh at existing pipe crossings are being installed upstream of the existing catch basins adjacent to these new manholes. The plans do not indicate that anything should be done to the existing catch basins. Unless modifications are made to the existing catch basins a certain amount of water will pool in the downstream catch basin before the water level rises enough to flow back upstream to the new junction box and then down the new storm drain and water will always

- hold in these two structures. Should any modifications be made to the existing catch basins at these two locations? Contractor is responsible to create positive drainage from the existing catch basin to the new junction boxes. Please see updated bid form for the addition of two (2) GDOT 1034D (668-1110) catch basins.
6. Are precast headwalls acceptable in lieu of cast in place headwalls? Yes, pre-cast structures may be used in lieu of cast in place headwalls. Please note that the front and back of all joints must be mudded.
 7. There appears to be a rear driveway from 924 Stoneleigh Road that exits onto Lakemont that will be affected by construction, however we do not see a pay item for replacement of this driveway. Please advise. Additional pay item has been added to address replacement of this driveway. Please see updated bid form.
 8. Stoneleigh Road currently has centerline and edge striping that will likely be damaged during construction. Will the contractor be required to replace any striping that is damaged? No, the striping will not be the responsibility of the contractor. The City will address these items after project completion.
 9. Who will be responsible for adjustment of any sanitary sewer and water services that may be in conflict with the work? Contractor shall make reasonable effort to avoid, or work around, any utility conflicts in coordination with utilities services. If conflict cannot be avoided, the contractor shall be responsible for adding a junction box at the contract unit rate, as directed by the City.
 10. The Phase 2 Erosion Control Plan shows Rt-B to be installed at the new outlet headwall of the pond. Will there be a pay item added for this work or should it be included in other pay items? Additional pay item has been added to address this. Please see updated bid form.
 11. The plans indicate that 4' tall fence should be installed and the pay items say 6' fence. Please confirm the required height of the proposed fence. The correct height for the fence shall be 6' - 0".

BY:

Megan Elliott
Project Engineer

Attachments:

- Revised Bid Form

###

**Revised Bid Form - Addendum 001 for PW-2021-BROOKWOOD
BROOKWOOD DRIVE FLOOD MITIGATION & STORMWATER IMPROVEMENTS PROJECT**

ITEM NO.	ITEM DESCRIPTION	UNIT	QUANTITY	UNIT PRICE	TOTAL
GRADING & ROADWAY ITEMS					
150-1000	TRAFFIC CONTROL	LS	1		
210-0100	GRADING COMPLETE	LS	1		
402-3100	RECYCLED ASPH CONC 9.5 MM SUPERPAVE, TYPE I, GP 1 OR BLEND 1, INCL BITUM MATL & H LIME	TN	35		
500-9999	CLASS B CONCRETE	CY	65		
441-0016	DRIVEWAY CONC., 6" THICK	SY	9		
441-6216	CONC CURB & GUTTER, 8 IN X 24 IN, TP 2	LF	100		
				SUB TOTAL	

DRAINAGE ITEMS					
207-0203	FOUND BK FILL MATL, TYPE 2 BACKFILL MATERIAL (WASHED 57s)	CY	200		
550-1150	15" RCP	LF	330		
550-1180	18" RCP	LF	517		
500-3107	CLASS A CONCRETE	CY	4		
600-0001	FLOWABLE FILL	CY	8		
668-1100	CATCH BASIN, GRP 1	EA	3		
668-2100	DROP INLET	EA	1		
668-4300	STORM SEWER MANHOLE, TP 1	EA	6		
				SUB TOTAL	

TEMPORARY EROSION CONTROL ITEMS					
163-0524	FILTER RING	EA	1		
163-0539	CONSTRUCT AND REMOVE - SLOTTED BOARD DAM W/ STONE	EA	1		
163-0550	INLET SEDIMENT PROTECTION	EA	7		
Non-Standard	CONCRETE WASHOUT	EA	1		
				SUB TOTAL	

PERMANENT EROSION CONTROL ITEMS					
603-2012	RIP RAP PAD OUTLET PROTECTION	TN	13		
700-6001	GRASSING COMPLETE	SF	22650		
				SUB TOTAL	

FENCING ITEMS					
643-1452	6' BLACK VINYL COATED CHAINLINK FENCE	LF	568		
643-8030	12' DOUBLE SWING GATE, BLACK VINYL COATED W/ LOCK	EA	1		
				SUB TOTAL	

Company Name: _____

Authorized Bid Rep. Signature: _____

Authorized Bid Rep. Title: _____

TOTAL